

# **San Pasqual Valley Unified School District**

## **Addendum to Cafeteria Generator Project**

### **Bid #2023-05**

This addendum to the Cafeteria Generator Project Bid #2023-05 consists of the changes listed below. As specified in the bid documents, these changes will move the bid deadline to a different date and time.

1. Bid submittal date: January 25, 2024 at 2:00 PM (AZ time)
2. Transfer switch location: The new automatic transfer switch location is South of building 105. The transfer switch will be located between existing transformer and new generator. It is required to include an outdoor transfer switch with proper enclosure to protect from elements and extreme temperatures.
3. Include recommended service agreement for at least one year.
4. Include at least a one year warranty.
5. Ensure generator, transfer switch and materials comply with all California regulations.
6. Ensure all trenching, electrical work, etc. complies with California regulations.
7. Include a sound attenuating enclosure installed on the generator that meets California requirements.
8. Generator should be able to run for at least 24 hours on 1 full tank of gas.
9. Install a maintenance bypass switch on the ATS.
10. Generator needs to have the ability to notify via text, phone, or email in the event of power failure.